

KAMAL VIHAR Co-Op GROUP HOUSING SOCIETY LTD. (Regd.)

Regd. Office: Plot No. 5, Sector -7, Dwarka Phase-1, New Delhi – 110075

Registration No: 848/GH/1983

Tel: 91-011-25080981, 42750141-42 Email Id – kamalvihardwarka@Gmailcom

Ref No - KV/CGHS/168/2025

Dated 07-11-2025

CIRCULAR


Dear Members,

Yesterday Delhi Fire Service (DFS) team visited our Society and inspected our Fire Fighting System. They found our System in good operational condition as per DFS norms. However on inspection of ground passage for their fire tenders movement and all our floors and roof tops to evacuate residents at the time of emergency. They refused to issue NOC at this stage on the grounds given below:

1. The passage between Temple and Block 5 is narrow for their vehicle movement.
2. Flower/ plant pots placed on the floors and staircase are blocking the passage for emergency exit of residents.
3. Wires of internet and Tvs installed on the roof tops of the blocks are placed in a very haphazard way which block free movements of the people at the time of evacuation/ emergency.

The team suggested to widen the passage between temple and the block 5, removal of all the flower pots from floors and stairs and wires from the roof tops. They have given two weeks time to do the needful. After that they will visit the society again and if found everything ok then only they will issue NOC.

Thanks & regards


Hemchander
(Secretary)